

FIRE EXTINGUISHERS - Galaxy Regular Dry Chemical - C - Portable Handheld

Standard BC dry chemical is a multipurpose that is suitable for use on flammable liquid hazards in areas such as light manufacturing facilities, vehicle/aircraft/marine service centers and retail stores



CLASS B FIRES

Flammable
Liquids
and Gases



CLASS C FIRES

Energized
Electrical
Equipment

SPECIFICATIONS:

These models contain a siliconized sodium bicarbonate base, the traditional dry chemical. Cleanup after use is generally easy, because the chemical does not normally bake to a hot metal surface. Non-toxic.

Conforms to Test Standards: CAN/ULC-S504—ANSI/UL299 & CAN/ULC-S508-ANSI/UL711


Operation: Squeeze the lever, which opens the valve, allowing the chemical to be forced out. Upright squeeze grip operation.

Temperature Range: -65° F (-53° C) to 120° F (49° C)

Construction: Heavy-duty steel cylinder with rugged metal valve and siphon tube with replaceable valve stem seal, visual pressure gauge pull pin and upright squeeze grip.

Valve Material: Aluminum

All units meet the current requirements established by the National Fire Protection Association (NFPA) for NFPA10 "Standard for Portable Fire Extinguishers", and any other applicable NFPA standards. Tested and listed by UL to meet construction and performance standards for this type of extinguisher, and can be used where required by local codes such as OSHA.

Qty.	Model	Type	Nominal Capacity	Shipping Weight	Cylinder Dia.	Overall Height	Overall Width	Shipping Vol	UL Rating 	Optional Mounting Bracket	USCG Approved
	Galaxy 2-1/2* (FG02C)	BC Dry Chemical	2-½ lbs.	5.5 lbs.	3-¾"	14-¾"	4-7/8"	.2 cu.ft.	10B:C	MB817C*	YES
	Galaxy 5-1/2 (FG055C)		5-½ lbs.	10.5 lbs.	4-¼"	16-¾"	7-¼"	.4 cu.ft.	40B:C	MB818C	YES
	Galaxy 10 (FG10C)		10 lbs.	18.25 lbs.	5-⅛"	21"	8-¾"	.65 cu.ft.	40B:C	MB846C	YES
	Galaxy 20 (FG20C)		20 lbs.	33.5 lbs.	7-½"	23-¼"	10-¼"	1.0 cu.ft.	120B:C	MB811C	YES

*Indicates mounting bracket standard. J hook wall bracket standard with all other extinguisher - mounting bracket available for those models at extra charge.

Note: NFPA regulations also require extinguishers to be inspected when initially placed in service and all local fire code and tagging requirements must be adhered to. All fire extinguisher sizes are nominal. Contact Customer Service for more information about ordering tagged extinguishers in your area.



9702 Newton Ave S. Bloomington, MN 55431



Distributor:

Contractor:

Date:

Scale: N/A

Project:

Approved By:

Architect:

Item #:

Pages: 1 of 1